



Report No	2400/8870083 Issue 2	This Report consists of 64 pages
Client	Ceasefire Industries Private Ltd E-6, Upside Industrial Area Selaqui Dehradun Uttarakhand 248197 India	
Authority & date	BSI Service Management Order No. 8870083 dated 22 November 2017	
Items tested	Automatic suppression system for small cabinets	
Specification	Client's own specification Direct Commission Testing	
Results	Pass - The Summary and conclusions of tests are given on Page 3 This Issue supersedes the previous Issue. The amendment giving rise to this Issue of the Report can be ascertained by contacting the authorising signatory.	
Prepared by	R Hearty 	Fire Team Leader
Authorised by	R Gurney 	Group Certification Manager
Issue Date	16 January 2017	
Conditions of issue	This Test Report is issued subject to the conditions stated in the current issue of CP0322 'Conditions of Contract for Testing'. The results contained herein apply only to the particular sample/s tested and to the specific tests carried out, as detailed in this Test Report. The issuing of this Test Report does not indicate any measure of Approval, Certification, Supervision, Control or Surveillance by BSI of any product. No extract, abridgement or abstraction from a Test Report may be published or used to advertise a product without the written consent of the Managing Director, BSI, who reserves the absolute right to agree or reject all or any of the details of any items or publicity for which consent may be sought.	

TESTING, EXAMINATION AND ASSESSMENT OF FIRE SUPPRESSION SYSTEMS SUBMITTED AS DIRECT COMMISSION TEST SAMPLES

INTRODUCTION

For the purposes of direct commission testing the Mini fire suppression systems detailed below, submitted on behalf of Ceasefire Industries Private Ltd., were tested and assessed against the requirements of the Client's own specification, as indicated on the following pages of this Report. This request was made on a BSI Service Management Order.

The tests and assessments contained in this Test Report were undertaken by BSI at the manufacturer's premises (A.I. Centre, Ceasefire Industries Pvt Ltd, Noida, India) between 11 and 12 December 2017.

IDENTIFICATION OF SAMPLES

Type:	Mini 100g and Mini 500g, "Intuitive" and "Adaptive" variants
Description:	Mini Fire suppression system using quartzoid bulb detection for the protection of small defined volume, single compartment and unoccupied enclosures
General assembly drawing number:	100g Intuitive CF/SP-CA100-VR/GA/00 100g Adaptive CF/SP-CA100-HR/GA/00 500g Intuitive CF/SP-CA500/GA/00 500g Adaptive CF/SP-CA500-HR/GA/00
Manufacturer:	Ceasefire Industries Pvt. Ltd.
Type and name of Extinguishing medium/media:	HFC227ea
Pressurisation (method/type):	Stored pressure (nitrogen)

REPORT

Test results see pages 4 to 12
Annex 1, 2, 3 and 4 see pages 13 to 64